



Materialprüfung und Entwicklung
GmbH & Co. KG

Geschäftsführer: Jens Hellberg
Artlenburger Landstraße 39 - 41
21365 Adendorf
Tel.: +49 4131 88 43 947
Fax: +49 4131 88 43 948
Email: hellberg@mpi-pruefinstitut.de
Internet: www.mpi-pruefinstitut.de

Test certificate No.: 12 10424 - S/ 21

Date: 19.11.2021

Page 1 of 2

Customer: GF General Formulations GmbH
Hansestrasse 105
51149 Cologne
Germany

Order No.: n.n.

Date of order: 15.11.2021

Type of test: Testing of floorcoverings in accordance with DIN 51130, Slip Resistance "Ramp Test".

Testing material:

Trade name: Self-Adhesive PVC-Free Raw floorfilm,
(declaration by customer) type: X-TEC X-Stripes

Format of test item: 100 cm x 50 cm (Length x Width)
(according to DIN 51130 / BGR181)

Surface structure: rough, with print

The pages 1 and 2 show the complete test result. They may just be published together



Test certificate No.: 12 10424 – S / 21

Page 2 of 2

Test

Date of test: 18.11.2021

Standards / regulations: **DIN 51130 (Version 2014-02):** Testing of floor coverings - Determination of the anti-slip property - Workrooms and fields of activities with slip danger - Walking method - Ramp test

Joint width of item for testing: 0 mm

Test result:

Average angle: >38,0°

Average displacement: not tested

Classification: R 13

Classification of displacement: not applicable

Validity of this certificate

Owing to possible changes in regulations (test / standards) and technical innovations, the validity of this certificate is limited for the duration of 5 years until the 18.11.2026.

The test results are only valid for products which are identical with the tested item. The correlation between the item tested and the production lot is not controlled by MPI test lab!

General informations

Certificates may only be copied and published with permission of the MPI test lab without any changes. The publishing and copying of shortened versions is only permitted after consulting with MPI test lab.



MPI Materialprüfung und Entwicklung
(Leitung Jens Hellberg)